




3000/3000T SERIES

T-BAR SKYLIGHT SYSTEMS
2" (50.8 mm) BASE WIDTH

G



Part 1 - GENERAL

Scope - The skylight framing system shall be _____ Series as manufactured by METRO ALUMINUM Products Ltd. Supply and install aluminum framing, as described on the architectural drawings and as specified herein.

Work Not Included - See: Specifier's lists of excluded items; Items furnished but not installed and/or Items installed but not furnished.

Related Work Specified Elsewhere - See: Specifier's lists and related Sections.

Design & Performance Requirements - Framing to fully comply with the applicable standard specifications as typically referenced to the following performance requirements criteria: Air Tightness, Water Tightness, Wind and Snow (and other applicable) Load Resistance, Temperature Index and Energy Performance. (Specifier's selection)

Submittals - Shop Drawings & Samples - Submit all documentation and samples for review by Consultant at one time, prior to fabrication of curtain wall products.

Quality Assurance - Provide all necessary information to show that all involved products meet or exceed the requirements of these specifications.

Delivery, Storage and Handling - Deliver, store, handle, protect and schedule materials and products so as to avoid any damage. Follow recommendations of AAMA CW-10 "Care and Handling of Architectural Aluminum from Shop to Site" and others as applicable.

Part 2 - PRODUCTS

Materials - All materials to meet the applicable minimum design and specifications requirements. Any defects impairing strength, durability or appearance are not acceptable. Extruded aluminum shall be AA 6063 T6 alloy and temper - $F_y = 110$ MPa (16 KSI) minimum. Sufficient strength and size assembly fasteners and anchoring bolts shall be made of corrosion-resistant and compatible material such as cadmium or zinc plated carbon steel or stainless steel. Separate incompatible materials and prevent galvanic action (electrolytic corrosion). Structurally adequate anchoring metal brackets shall be anticorrosive painted. Glass-to-metal contact is not acceptable.

3000/3000T Series - Glazing shall utilize standard interior extruded PVC gaskets and exterior rolled aluminum glazing beads as required for conventional dry-dry, outside glazing method with 2-side supported glass.

3400/3400T Series - Glazing shall utilize standard gaskets, dense interior and sponge exterior, shall be extruded from Neoprene, EPDM, or other equal material as required for conventional dry-dry, outside glazing method with 4-side supported glass. Gasket profiles shall be designed and sized to uniformly fit tight and properly seal glass-metal interfacing. Acceptable gasket compression range to be 0.7 to 1.7 kN/m (4 - 10 lbs/in).

Glass setting to be compatible with glass unit seals and/or other parts involved as required.

System Description - Framing Systems (Specifier's selection)

Reference face width dimension of extruded profiles shall be 2" (50.8 mm).

3000/3000T METRO Series - as manufactured by METRO ALUMINUM Products Ltd. - Conventional T-bar uninsulated (thermally broken/insulated) with internal drainage system and continuous anchor sill shoe for single glass and sealed insulating glass units, allowing for full integration with the rainscreen part of building envelope. Glass retention, as for dry-dry glazing method, shall be achieved by exterior glazing bead (retainer) profile. Glass hard bite to be 9.5 mm (0.375") minimum.

3400/3400T METRO Series - as manufactured by METRO ALUMINUM Products Ltd. - Thermally broken/insulated, tubular with internal drainage system for sealed insulating glass units or single glass, utilizing Rainscreen Principle and allowing for full integration with the building envelope. Purlins to be equipped with condensation gutters as required. Glass retention, as for dry-dry glazing method, shall be achieved by 4-side pressure plate (retainer) profile and inorganic rubber gasket. Glass hard bite to be 12.7 mm (0.5") minimum.

Whenever substitute/alternative products are considered, supporting data to be submitted ten (10) days prior to bid date to allow for valid comparison. Approval of alternates to be confirmed in advance of bid closing by addendum only.

Fabrication - Extruded profiles shall be accurately fabricated and assembled and sealed to provide air/water tight fit hairline joints only. Fastening shall allow for permanent true and square set of frame elements. Assembly shall utilize concealed screws only. Properly sealed frame assembly joints to result in continuity of air barrier on the system's inside side. Frame assemblies shall be free of warp. Uniformly compressed glazing gaskets shall secure glass in place. No exposed fasteners are permitted.

Finish - All exposed surfaces shall be finished as specified. The finish, as per AAM designation, shall be (Specifier's selection):

Standard clear anodizing to AA - M12C22A31

Standard perma bronze to AA - M12C22A44

Standard black anodizing to AA - M10C21A44

Duracron acrylic enamel to AA - M12C4XR1X

Custom paint qualities and colors - Specifier's selection.

Part 3 - EXECUTION

Installation - Steel embeds and anchoring brackets to be placed and ready as required. Anchoring shall suit perimeter conditions of rough openings and seals as required. Prefabricated framing to be installed at prepared structure, at correct locations as shown on drawings, set with required reference to level, plumb, square and aligned with other work in accordance with manufacturer's instructions, approved shop and erection drawings. Perimeter joints to be sealed/caulked as specified and detailed to ensure weathertight assembly.

Protection and Cleaning - Work to be protected from damage during and after installation. Consult with manufacturer and installer to determine appropriate protective measures. The General Contractor shall be responsible for protection during construction and for final cleaning. After installation, aluminum work and glass to be cleaned according to instructions/manuals provided by product manufacturers and glaziers. Use appropriate cleaning materials and methods. Do not scratch or damage glass or finishes.











**METRO
ALUMINUM**
Products Ltd.

3000/3000T SERIES

T-BAR SKYLIGHT SYSTEMS
2" (50.8 mm) BASE WIDTH

**G
02**

COMPONENTS





DETAILS

