



TESTING IN ACCORDANCE – ASTM E283					
AIR LEAKAGE	TEST PRESSURE	INFILTRATION	EXFILTRATION	OVERALL RESULT	NAFS 2017 REPRESENTATIVE LEVEL
	75PA	0.037 L/S/M2 0.007 CFM/FT2	0.021 L/S/M2 0.004 CFM/FT2	PASS	FIXED LEVEL

TESTING IN ACCORDANCE – ASTM E547			
WATER PENETRATION	TEST PRESSURE	OVERALL RESULT	NAFS 2017 PG LEVEL
	720 PA (15.00 PSF)	PASS	PG100

The above results relate only to the product configuration tested. Every effort has been taken to accurately report the performance of the material, however, due to large amount of input data and reliance from outside sources, it is possible that some errors and/or omissions may occur.