



TESTED IN ACCORDANCE WITH - CSA-A440 – NFRC THERMAL SOFTWARE					
THERMAL DATA – 6mm SB70XL LOW E #2//6mm CLEAR					
U-VALUE	W/M2-K	BTU/H-FT2F0	SHGC	CI	VT
	1.978	0.348	0.245	N/A	0.562

TESTING IN ACCORDANCE – ASTM E283					
AIR LEAKAGE	TEST PRESSURE	INFILTRATION	EXFILTRATION	OVERALL RESULT	NAFS 2017 REPRESENTATIVE LEVEL
	75PA	0.037 L/S/M2 0.007 CFM/FT2	0.021 L/S/M2 0.004 CFM/FT2	<b>PASS</b>	<b>FIXED LEVEL</b>

TESTING IN ACCORDANCE – ASTM E547			
WATER PENETRATION	TEST PRESSURE	OVERALL RESULT	NAFS 2017 PG LEVEL
	720 PA (15.00 PSF)	<b>PASS</b>	<b>PG100</b>

The above results relate only to the product configuration tested. Every effort has been taken to accurately report the performance of the material, however, due to large amount of input data and reliance from outside sources, it is possible that some errors and/or omissions may occur.